

Building (Scotland) Regulations 2004 Regulation 5, Schedule 3

Guidance on electrical work not requiring a warrant



DOMESTIC BUILDINGS	WORK TO EXISTING BUILDINGS			
	type [1]	flat	house (up to 2 storeys)	house (3 storeys & above)
Repairs and replacement				
Re-wiring [2]	24	required	not required	required
Electrical fixtures, eg luminaries	24	not required	not required	not required
New work				
Electrical work affected by demolition or alteration of the roof, external walls or elements of structure	1	required	required	required
Electrical work adversely affecting a separating wall, eg recessed sockets	1	required	required	required
New power socket outlets	1	required	not required	required
Mains operated fire alarm system	1	required	not required	required
Electrical work to automatic opening ventilators (including auto-detection)	1	required	not required	required
Electrically operated locks	1	required	not required	required
Wiring to artificial lighting	1	required	not required	required
Wiring to emergency lighting	1	required	not required	required
Electrical work associated with sprinkler system	1	required	not required	required
Electrical work associated with new boiler (large)	1	required	not required	required
Electrical work associated with new boiler (small)	6	not required	not required	not required
Electrical work associated with new shower	11, 12	not required	not required	not required
Electrical work associated with new extract fan	13	not required	not required	not required
Extra low voltage installations	22	not required	not required	not required

Note 1 Building work type as referenced in schedule 3.

Note 2 A building warrant is not required for rewiring where it is a repair or replacement works to a level equal to the installation (or part thereof) being repaired or replaced.



Building (Scotland) Regulations 2004 Regulation 5, Schedule 3

Guidance on electrical work not requiring a warrant



NON-DOMESTIC BUILDINGS	WORK TO EXISTING BUILDINGS			
	non-residential buildings with a storey, or creating a storey, not more than 7.5 m			other non-
				domestic
	type [1]	no public access	public access	buildings
Repairs and replacement				
Re-wiring [3]	24	not required	required	required
New work	•			
Electrical work affected by				
demolition or alteration of the	2	roguirod	required	roguirod
roof, external walls or elements		required	required	required
of structure				
Electrical work adversely				
affecting a separating wall, eg	2	required	required	required
recessed sockets		•	•	•
Electrical work adversely	2	no avviso d	required	required
affecting a loadbearing wall		required		
New power socket outlets	2	not required	required	required
Automatic fire detection system	2	not required	required	required
Electrical work to automatic	2	not required	required	required
opening ventilators				
Electrical work to automatic fire	0	not required	required	required
dampers	2			
Electrically operated locks	2	not required	required	required
Wiring to artificial lighting	2	not required	required	required
Wiring to emergency lighting	2	not required	required	required
Outdoor luminous tube signs [4]	2	not required	not required	not required
Electrical work associated with	2	not required	required	required
new boiler (large)	2			
Electrical work associated with			not required	not required
new boiler (small)	6	not required		
Electrical work associated with	44.40			
new shower	11,12	not required	not required	not required
Electrical work associated with	40		,	
new extract fan	13	not required	not required	not required
Extra low voltage installations	22	not required	not required	not required

- Note 1 Building work type as referenced in schedule 3.
- **Note 2** Non-residential buildings to which the public does not have access may include:
 - Existing offices
 - Existing storage buildings
 - Existing industrial buildings e.g. factories and workshops
 - Existing assembly and entertainment buildings not open to the public e.g. some educational buildings and private members clubs.

Non-residential buildings to which the public has access may include:

- Existing assembly and entertainment buildings open to the public e.g. community schools, pubs and clubs.
- **Note 3** A building warrant is not required for rewiring where it is a repair or replacement works to a level equal to the installation (or part thereof) being repaired or replaced.
- Note 4 subject to the Town and Country Planning (Control of Advertisement)(Scotland) Regulations 1984.